

# Alarm Chart



## Alarms in MyChild6

**Patient Alarms** are alarms that are triggered by assigned tags under certain conditions. These alarms will pop up on your floorplan and point to the device that triggered that alarm or saw the patient's name, tag number, and last known location.

**Level 1** alarms notify you about events that could lead to a security breach. These alarms will pop up as notifications that disappear after 30 seconds unless you click "View Alarm" in the floorplan view. The floorplan view has priority over all other pages in the system; therefore, whatever you are working on before clicking on "View Alarm" because you will be taken to the alarm details page.

**Level 2** alarms also notify you about events that could lead to a security breach. These alarms will pop up as notifications that disappear after 30 seconds unless you click "View Alarm" in the floorplan view. The floorplan view has priority over all other pages in the system; therefore, whatever you are working on will not be saved. Audio is included for these alarms.

**Level 3** alarms notify you about events that could be security breaches. These alarms will pop up as notifications that disappear after 30 seconds unless you click "View Alarm" in the floorplan view. The floorplan view has priority over all other pages in the system; therefore, whatever you are working on will not be saved. Audio is included for these alarms.

Alarm Name	Level	Alarm Description	Setting Configuration
TAG NEAR CLOSED DOOR	1	This alarm occurs when an assigned tag that is NOT in Bypass Mode is in a protected door field and the door is closed. This alarm self-accepts when the tag is no longer in the door field. If the door opens while the tag is in the field, this alarm gets replaced by a TAG NEAR OPEN DOOR alarm. If the door remains closed but the tag is still in the field for more than one minute, this alarm is replaced by a TAG LOITERING NEAR DOOR alarm.	Yes. You can enable or disable this alarm at individual doors.



Alarm Name	Level	Alarm Description	Setting Config
TAG LOITERING NEAR DOOR	2	This alarm occurs when an assigned tag that is NOT in Bypass Mode is in a door field for longer than one minute and the door is closed. It replaces the TAG NEAR CLOSED DOOR alarm.	Yes. Y disabl indivi doors
TAG NEAR OPEN DOOR	3	This alarm occurs when an assigned tag that is NOT in Bypass Mode is in the field of an open door.	No
TAG NEAR ELEVATORS - DOORS CLOSED	3	This alarm occurs when an assigned tag NOT in Bypass Mode is in a bank style elevator field and the elevator doors are all closed. In a standard design, the elevators do not stop on the floor where the tag is when this alarm is active.	No
TAG NEAR ELEVATORS - DOOR OPEN	3	This alarm replaces "TAG NEAR ELEVATORS - DOORS CLOSED." This alarm occurs when an assigned tag NOT in Bypass Mode is near bank style elevators, and a motion detector at an elevator door detects motion, thereby indicating the elevator door is open. In a standard design, the elevators are disabled on the floor where the tag is when this alarm is active.	No
TAG IN ELEVATOR	3	This alarm occurs when an assigned tag NOT in Bypass Mode is in the field of an individual elevator controller. In a standard design, the elevator door will stay open, and the elevator will not move when this alarm is active.	No





Alarm Name	Level	Alarm Description	Setting Configurable
PATIENT EXIT UNAUTHORIZED BY MYCHILD	2	This alarm occurs when someone enters a correct PIN code at a door and there is an assigned tag in the door field and that tag is NOT in Bypass Mode. The egress is authorized by the hospital because the correct PIN was entered; however, the egress is unauthorized by MyChild.	This alarm can be turned on or off for individual doors.
TAG OUTSIDE OF PROTECTED AREA	3	This alarm occurs when a tag is picked up by a receiver located outside of a protected unit/zone.	No
TAG TAMPER	3	This alarm occurs when the circuit formed by the connection of a cut-band and a cut-band tag is interrupted OR the sensing mechanism on the tag no longer senses that it is on skin.	No
TAG SIGNAL MISSED	1	This alarm is triggered when the system does not receive any TLM signals from an assigned tag for a configurable time period.	Yes. You can choose how many seconds should elapse without hearing from an assigned tag to trigger this alarm. The default is 30 seconds.
TAG SIGNAL MISSED 2	2	This alarm is raised after a configurable period of time after a Tag Signal Missed.	Yes. You can choose how many seconds should elapse after a Tag Signal Missed.





**Bypass Alarms:** MyChild provides a ByPass Mode that allows you to take a patient without setting off alarms. You must select a departing unit and a destination. When a patient status changes from “Active” to “Bypass” when a patient is in ByPass Mode.

When the time allotted for the bypass is almost expired, a “BYPASS EXPIRING” alarm is triggered. When the timer reaches zero, a “BYPASS EXPIRED” alarm is triggered. All bypass alarms can be edited by you to edit the bypass. Changes can also be made on the patient card. When the alarm is “Complete,” you are acknowledging that the patient has arrived at the destination.

Alarm Name	Level	Alarm Description	Setting Configurable
BYPASS STARTED	1	The first bypass-designated door passed by a patient in bypass triggers this alarm and starts the bypass timer.	No
BYPASS EXPIRING	1	<p>This alarm occurs five minutes before a patient in bypass is due to pass the second bypass door (destination).</p> <p>If the patient passes the second bypass door during the five-minute period, this alarm is replaced by a “BYPASS COMPLETE” alarm.</p> <p>If five minutes pass and the patient has not passed the second door, this alarm is replaced by a “BYPASS EXPIRED” alarm.</p>	You may select how many minutes before the bypass timer expires to raise this alarm. The default is five minutes.
BYPASS COMPLETE	1	This alarm occurs when the patient in bypass passes the second bypass door.	No





**Suspend Tamper Alarms:** MyChild provides a suspend tamper function to temporarily suspend a patient's sensing tag temporarily without setting off alarms. When you put a patient into suspend tamper mode, the patient status changes from "Active" to "Tamper Suspended."

When the time allotted for the suspend tamper is almost expired, a "SUSPEND TAMPER EXPIRING" alarm is triggered. When the timer reaches zero, a "SUSPEND TAMPER EXPIRED" alarm is triggered. These alarms allow you to edit the suspend tamper. Changes can also be made to the suspend tamper settings.

*When you click "Complete" to complete a Suspend Tamper, you are acknowledging the patient.*

Alarm Name	Level	Alarm Description	Setting Configurable
SUSPEND TAMPER STARTED	1	This alarm notifies you that a patient has been put into Suspend Tamper Mode and that the Suspend Tamper timer has started.  The patient status changes from "Active" to "Tamper Suspended."	No
SUSPEND TAMPER EXPIRING	1	This alarm appears five minutes before the suspend tamper allotted time is due to expire.  At this point you can edit the tamper suspend to add time or complete the tamper suspend.	You may select how many minutes before the timer reaches zero to raise this alarm.





**Device Alarms** are alarms that are triggered by door controllers, receiver Input/Output devices (I/Os) under certain conditions. Device alarms show the device that triggered the alarm.

**Level 1** alarms notify you about events that could lead to a security breach. Level 1 alarms trigger pop-up notifications that disappear after 30 seconds unless you click on them. Level 1 alarms are displayed in the floorplan view. Floorplan view has priority over all other views. Therefore, whatever you are working on before clicking on a level 1 alarm because the floorplan view takes over your screen.

**Level 2** alarms also notify you about events that could lead to a security breach. Level 2 alarms trigger the events that trigger a level 1 alarm. There are no pop-up notifications for level 2 alarms. A level 2 alarm automatically takes over your screen; therefore, whatever you are working on will not be visible. Audio is included.

**Level 3** alarms notify you about events that could be security breaches. Level 3 alarms trigger protocols to be followed. There are no pop-up notifications. The floorplan view takes over your screen; therefore, whatever you are working on will not be visible.

Alarm Name	Level	Alarm Description	Setting Configurable
LOW BATTERY TAG IN INVENTORY	1	This alarm is triggered when a tag that is not assigned to a patient sends a Tag Initiated Communication (TIC) message of low battery. The closest device to this tag reports this.	You can change the number of TIC messages received before triggering this alarm.
GLOBAL LOCKDOWN OFFLINE	2	This is for I/O devices.	The number of signals missed within a certain time period can be configured.



Alarm Name	Level	Alarm Description	Setting C
DOOR CONTROLLER OFFLINE	2	MyChild continuously requests status from each door controller. No response from a door controller triggers this alarm. When a door controller is offline, it still locks when a tag is in the field; however, users will not see door-related alarms on their workstations. Of course, if a door is offline due to a loss of power it will not lock when a tag is in the field.	You can c number c before tri alarm. Th signals (a seconds).
BYPASS DEVICE OFFLINE	2	This is for doors that are designated Bypass Doors and tag detectors utilized for Bypass.	You can c number c before tri alarm. Th signals (a seconds).
INVALID PIN ENTERED	2	This alarm occurs when too many incorrect bypass PIN codes are entered on a MyChild keypad.	Yes. The attempts which the can be m configure 3 tries in
ANTENNA DISCONNECTED	3	This alarm means that <b>doors will not lock!</b> MyChild software continuously requests status from each door controller. If an antenna is disconnected, this message is included with the status, triggering	You can s of exciter disconne within a c period to alarm. Th



Alarm Name	Level	Alarm Description	Setting Configuration
WIRELESS RECEIVER OFFLINE	1	MyChild software continuously requests status from each device. No response from a wireless receiver triggers this alarm. This is usually a temporary network issue.	Yes. You can select how many signals are missed in a configurable time period. The default is 30 signals in 30 seconds.
RECEIVER OFFLINE	1	MyChild software continuously requests status from each device. No response from a wired receiver triggers this alarm. This is usually a temporary network issue.	Yes. You can select how many signals are missed in a configurable time period. The default is 30 signals in 30 seconds.



**System Alarms** appear to those with the relevant credentials in their p can gain access through profile customization. System alarms also gen technical support so that McRoberts technicians can initiate troublesh

Alarm Name	Level	Alarm Description	Setting Configurable?
NETWORK IN DEGRADED STATE	1	This alarm occurs when, during a five-minute period, there are three or more ping failures OR average ping latency is 0.5 milliseconds or greater. A ping is an echo request sent from the server to the INM. Latency is the amount of time it takes for the request to occur measured in milliseconds.	No
NETWORK OFFLINE	2	This alarm occurs when there is an interruption in power or communications in the MyChild network. This is a security risk because without connection to the server, MyChild loses its functionality, so users don't see important alarms. This condition does not impact physical security. The doors operate independently and still lock and alarm when a tag is in proximity.	No





**Level 0** alarms are notifications that do not indicate a security risk and

Alarm Name	Level	Alarm Description
TAG AUTO-ENROLLED IN SYSTEM	0	This notification is logged when a tag auto-en
PATIENT ENROLLED	0	This notification is logged when a patient enr
PATIENT UPDATED	0	This notification is logged when patient infor
PATIENT UNENROLLED	0	This notification is logged when a patient is u
PATIENT LOCATION DISPLAYED	0	This notification is logged when the LOCATE f
BYPASS CREATED	0	This notification is logged when a bypass is cr start the bypass timer; however, the patient :
DOOR BYPASSED	0	This message occurs as part of the normal bypa bypass door. This initiates the bypass timer.
PATIENT BYPASS ENDED	0	This notification is logged when a patient pas completes the bypass.
SUSPEND TAMPER COMPLETED	0	This notification is logged when the suspend status goes back to "Active."
DEVICE BUFFER OVERFLOW	0	This notification is triggered by the devices whe This is self-healing and no user action is require
PIN ENTRY ACCEPTED	0	This notification is triggered anytime a valid PIN this is logged as an informational message.
DEVICE PIN CHECKSUM FAILURE	0	This notification is triggered when the door con internal PIN database. This is normally a self-he where power cycling the device and/or restarti
CONTROLLER /	0	These notifications are normally triggered imm



[Click here to download the Alarms Chart](#)

---

Revision #2  
Created 4 April 2023 18:06:58 by Anna Olt  
Updated 29 July 2024 21:17:46 by Anna Olt